



Addendum Number 1

December 9, 2022

From: Procurement Department

Re: Waste Water Treatment Plant Centrifuge Repair Services

Issue Date: November 27, 2022

Due Date: December 15, 2022

Please see the following questions & answers as well as the following updated price proposal form:

1. Besides standard hand tools provided by the company selected for this project (Onsite DCI - disassembly, cleaning and inspection service) What machine specific tools are onsite to be used for the proper dismantling of the centrifuges such as the scroll lifter? **No machine specific tools onsite**
2. Onsite Overhead Crane in Good Working Order? Can contractor operate it? **Yes and Yes**
3. Onsite Pressure Washing? I assume done by city staff? **No**
4. Is there any assistance from City maintenance staff whatsoever for disassembly and removal? **Removal of covers**
5. Will the rotating assemblies be pre-removed from their bases prior to the DCI by contractor? **No**
6. How deep of a DCI do you want to go onsite? Just enough for basic assessment including scroll removal? **Basic assessment that identifies the problem**
7. Will rotating assemblies be properly flushed prior to disassembly? **If able yes**
8. Machines carbon steel or stainless steel? **Stainless steel bowl**
9. Can the contractor leave a locked job / tool box onsite during the length of the contract? **Yes**
10. Upon DCI and shipment to facility for full service and rehabilitation, will any work required to cleaning of the base frames and housings, service of lube systems (oil & filter) or service of hydraulics (oil & filter) be performed by the City Staff? **Yes**
11. Do you have past maintenance records (DCI reports, Pictures, etc.) of these machines with pictures of the layouts and nameplates? Past Bids available online? **No**
12. Remove language in Section A, Number 3, Part E.
13. Remove language in Section B, Item 1, regarding "Contractor must supply only original equipment manufacturer (OEM) parts and equipment."
14. Remove language in Section B, Item 2, regarding "vehicle information".
15. Use the attached updated price proposal form in lieu of original.



End of Addendum Number 1

Appendix A

RFP Proposal Form

Centrifuge

Provide price per hour for dismantling, cleaning, inspecting, and photos. Provide digital photographs of unit as received, and any damage found (photographs become property of the City) before the unit leaves WWTP. \$ _____

Provide price per hour for centrifuge rotating assembly repairs. \$ _____

Provide price per hour for centrifuge Viscotherm Rotodiff gearbox repairs. \$ _____

Provide total price for transportation of centrifuge and equipment. \$ _____

Note: The items listed above include all support items listed in Section B.1. Scope of Service

COMPANY: _____

ADDRESS: _____

TELEPHONE: _____

EMAIL: _____

AUTHORIZED
SIGNATURE: _____

PRINT NAME: _____

DATE: _____

THIS PROPOSAL FORM MUST BE SIGNED TO BE VALID.