



Architectural
Services

130 Regional Park Drive
Kingsport, TN 37660
Phn (423) 349-7760
Fax (423) 349-7413
www.grcinc.com

ADDENDUM TWO

Project: **Kingsport City Schools, Tribe Athletic Complex Roof Re-Roof**

Address: **2533 N. John B. Dennis Highway, Kingsport, Tennessee.**

February 15, 2024

This Addendum is part of the Contract Documents for the above referenced project and modifies the original drawings and/or specifications, dated **1/23/24**, as noted below. The bidder shall acknowledge receipt of this Addendum in the place provided in the Bid Form. The published bid date and time shall remain the same.

GENERAL:

1. None

DRAWINGS:

1. **None**

SPECIFICATIONS:

1. **Section 075407 – TPO RETROFIT ROOFING – Part II, 2.02.B.2.** The Top Layer of insulation is intended to be a single layer of 25PSI 2” thick Polyisocyanurate High Density insulation with the C1289, Type II, Class 1, Grade 3 is a 25 psi Glass Reinforced felt facer.

END OF ADDENDUM 2