



**THOMPSON
& LITTON** EST.
1956

ENGINEERS ARCHITECTS SURVEYORS



ADDENDUM NO. 002

TO: All Plan Holders

RE: Renovations to the Nancy Pridemore Little Theater
Dobyns-Bennett High School
Kingsport, Tennessee

Project 17344

DATE: 4/24/2024

The original Specifications and Drawings dated March 2024, for the above referenced project are amended as noted in this Addendum Number Two. Receipt of this Addendum Number Two should be acknowledged by completing the Bid Form section referring to receipt of Addenda. This Addendum consists of one (1) page and one (1) attachment.

DRAWINGS

- ADD 2-1** Refer to drawing A100 RENOVATION MAIN FLOOR PLAN AND UPPER FLOOR PLAN AND NOTES. Please see the attached A100 RENOVATION MAIN FLOOR PLAN AND UPPER FLOOR PLAN AND NOTES which clarifies a few items on the new flooring finishes.
- ADD 2-2** Refer to drawing D100 DEMOLITION MAIN FLOOR PLAN AND UPPER FLOOR PLAN AND NOTES and A100 RENOVATION MAIN FLOOR PLAN AND UPPER FLOOR PLAN AND NOTES. Please note that the steps from the main floor to the stage (On either side of the stage) are to have the existing carpet removed and new carpet installed.
- ADD 2-3** Refer to drawing D100 DEMOLITION MAIN FLOOR PLAN AND UPPER FLOOR PLAN AND NOTES and A100 RENOVATION MAIN FLOOR PLAN AND UPPER FLOOR PLAN AND NOTES. Please note that the existing conduit that runs at the top of the balcony rail will need to be relocated inside of the balcony rail when it is dropped to the lower height.
- ADD 2-4** Refer to drawing A100 RENOVATION MAIN FLOOR PLAN AND UPPER FLOOR PLAN AND NOTES. Please note, based on a question, that the height of the side walls of the theater are, at most, 38' tall. However, this height will vary based on the floor slope and the ceiling soffit slope.

END OF ADDENDUM NO. 002