



**THOMPSON
& LITTON** EST.
1956

ENGINEERS ARCHITECTS SURVEYORS



ADDENDUM NO. 002

TO: All Plan Holders

RE: Dobyms-Bennett High School
Phase 1 Renovation
Project 19800

DATE: 5-5-2026

The original Specifications and Drawings dated 4/16/2026, for the above referenced project are amended as noted in this Addendum Number Two. Receipt of this Addendum Number Two should be acknowledged by completing the Bid Form section referring to receipt of Addenda. This Addendum consists of three (3) pages and three (3) attachments.

GENERAL

- ADD 2-1** As a general note, the last addendum will be sent the bidders by 4:00 PM on Wednesday, May 6, 2026. Please have any additional questions or comments to me by 1:00 PM on May 6, 2026.
- ADD 2-2** As a general note, for Alternate Bid Item No. 9A and Alternate Bid Item No. 9B please include the following for the existing ceiling tile and grid removal and reinstallation to run new IT wiring above the ceilings:
- Alternate Bid Item No. 9A – 800 square feet
Alternate Bid Item No. 9B – 1600 square feet

DRAWINGS

- ADD 2-3** Refer to drawing AD102B SECOND FLOOR DEMOLITION PLAN – EAST WING and A102B SECOND FLOOR PLAN – EAST WING. Please note that when the existing epoxy is removed from this area that the existing concrete will need to potentially have Ardex or similar installed prior to the new LVT flooring being put in place – Please confirm the method by which the epoxy is removed as some epoxy removal methods may not require.
- ADD 2-4** Refer to drawing AD102B SECOND FLOOR DEMOLITION PLAN – EAST WING and A102B SECOND FLOOR PLAN – EAST WING. Please note, in order to install the new showers in E203A, E204A, and E205A, that the existing concrete will need to be ground in order to allow water to drain to the floor drains in each space. And to allow for the porcelain tile to be installed per ADA guidelines for floor transitions.



5-5-2026

Page 2

Also of note, the showers in E203A, E204A, and E205A are to have porcelain tile installed on the floors and walls. Please address the porcelain tile using the attached Crossville Access Point Porcelain Stone with 2"X2" Mosaics on the floor and 12"x24" on the walls up to 7'-0" A.F.F. Please include the manufactures full range for this tile.

Please contact Lisa Hall with Crossville Tile for information on this tile at:

Lisa Hall - (423)-956-5286 LHall@loutile.com

- ADD 2-5 Refer to drawing A102B SECOND FLOOR PLAN – EAST WING and A402 ENLARGED CLASSROOM INTERIOR ELEVATIONS. Please note that in CLASSROOM E205 that the casework on the East wall is new casework. Please see 1/A402 INT. ELEV. – CLASSROOMS E203 & E204 KITCHENETTE, TYP. detail and add CLASSROOM E205 to this detail for the new casework.
- ADD 2-6 Refer to drawing AD101C FIRST & SECOND FLOOR DEMOLITION PLAN & RCP – ADMINISTRATION AREA and A101C FIRST & SECOND FLOOR PLAN & RCP – ADMINISTRATION AREA. Please note that the existing carpet flooring and base in the Classroom noted "NOT WITHIN SCOPE" to the right of the floor logo on A101C FIRST & SECOND FLOOR PLAN & RCP – ADMINISTRATION AREA is to have the same LVT and wall base shown to be installed in Corridor C000.
- ADD 2-7 Refer to drawing I105 INTERIOR FINISH PLAN – ALTERNATE #1, ADMIN AREA. Please note, based on a question, that the flooring in Lobby A052 should be LVT-1.
- ADD 2-8 Refer to drawing I105A INTERIOR FINISH PLAN – ALTERNATE #1, ADMIN CORRIDOR Please note, based on a question about the logo in the Admin Corridor, please see the below:
- This is made of cut LVT used throughout the project.
- Patcraft provided the drawings with the logo cutout located in our drawing set.
- ADD 2-9 Refer to drawing P101 1ST & 2ND PLUMBING NEW WORK PLAN. Please see that PLUMBING NOTES:, 1, says the following:
1. ONLY REPLACE DF-1 DRINKING FOUNTAINS IF ALTERNATE #3 IS ACCEPTED.



Addendum No. 002
Dobyys-Bennett High School
Phase 1 Renovation

5-5-2026

Page 3

Please change to say:

1. IF ALTERNATE #3 IS ACCEPTED, PLEASE REMOVE THE DRINKING FOUNTAINS NOTED, CAP THE PLUMBING, AND REPAIR/PAINT THE WALL AS REQUIRED. PLEASE SEE THE ALLOWANCE IN THIS ALTERNATE WORK.

SPECIFICATIONS


ADD 2-10 Refer to SECTION 01 2100 ALLOWANCES. Please see the attached which modifies the above section. Please also note that under 1.3 ALLOWANCES SCHEDULE, items A., B., and C. should be applied to the BASE BID costs.

ADD 2-11 Refer to SECTION 09 6510 VINYL BASE. Please note, based on a question, that the vinyl base to be used on the project will be 6" in the colors specified on the drawings.

ADD 2-12 Refer to SECTION 10 2800 TOILET, BATH, AND LAUNDRY ACCESSORIES. Please see the attached section which was inadvertently left out of the project manual.

END OF ADDENDUM NO. 002

Access Point Porcelain Stone®



Available Colors



WBT01 ▶ Travertine White



WBT04 ▶ Travertine Sand



WBT05 ▶ Travertine Dove



WBT06 ▶ Travertine Ash



WBC01 ▶ Concrete White



WBC04 ▶ Concrete Sand



WBC05 ▶ Concrete Dove



WBC06 ▶ Concrete Ash



WBS01 ▶ Statuario

Features and Benefits

- Get immediate access to great design with Access Point, Crossville's collection of always-on-point and in-stock genuine porcelain tiles
- Featuring some of today's most sought-after looks – including Concrete, Statuario, and white marble visuals
- Access Point is perfect for price-conscious projects and those seeking made in the USA products
- All Access Point tiles are calibrated in 12x24 and are balanced with 2x2 mosaics and 4x24 bullnose pieces all manufactured in Crossville, TN

Access Point Porcelain Stone®

Sizes *Available in all colors*

12 x 24



2 x 2 Square Mosaic
(Mounted on a
12 x 12 sheet)

Sizes & Finishes

Field Tile - Calibrated

Available in all colors

Nominal (in)	Actual (in)	Thickness (mm)	Grout Joint (in)	Finish
12 x 24	11-13/16 x 23-13/16	8.5	3/16	UPS

Note: Field tile is calibrated with a 3/16 inch grout joint

Mosaics

Available in all colors

Nominal (in)	Sheet Size (in)	Thickness (mm)	Grout Joint (in)	Finish
2 x 2 Mosaic*	11-15/16 x 11-15/16	8.5	3/16	UPS

* Mounted on a 12 x 12 sheet

Coordinating Trim

Available in all colors

Nominal (in)	Actual (in)	Thickness (mm)	Grout Joint (in)	Finish
4 x 24 Single Bullnose	3-13/16 x 23-13/16	8.5	3/16	UPS



4 x 24 Single Bullnose

Product Performance

Breaking Strength	>400 lbf	ASTM C648
Bond Strength	>200 psi	ASTM C482
Facial Dimension	± 0.15%	ASTM C499
Range of Thickness	0.025"	ASTM C499
Warpage	± 0.20%	ASTM C485
Wedging	± 0.30%	ASTM C502
Chemical Resistance	Unaffected	ASTM C650
Frost Resistance	Resistant	ASTM C1026
Water Absorption	<0.50%	ASTM C373
Scratch Hardness	7	Mohs Scale

Wet Dynamic Coefficient of Friction Range

UPS	0.42-0.52	ANSI A326.3
-----	-----------	-------------

Get Planked!

Our Porcelain Stone® products are available in popular plank shapes with no minimum order and quick fulfillment. See website for more details and sizes.



Shade & Texture Index

Access Point Concrete and Statuario has a shade variation of V2.
Access Point Travertine has a shade variation of V3.

V1	V2	V3	V4	V1 Uniform appearance
				V2 Slight Variation
				V3 Moderate Variation
				V4 Substantial Variation

This porcelain tile product is produced with a V2 variation. Expect that the amount of color and texture on each piece may vary slightly. Inspect the product upon delivery and for best results, blend tile from several cartons during installation.



Access Point

Crossville, Inc.

PO Box 1168
Crossville, TN
38557

Phone 931.484.2110
Fax 931.456.2956
E-Mail Crossc@CrossvilleInc.com
Web CrossvilleInc.com

Application Areas

Finish	Interior Floors (dry)	Interior Walls (wet/dry)	Exterior Walls	Interior Floors (Standing water/shower floors)	Exterior/Paving	Pool/Fountain Full Lining**	Water Line Pool/Fountains
UPS	✓	✓*	✓			✓	✓

* The 2 x 12 mosaic can be used in linear drain shower pans as long as the 12 inch side runs parallel to the drain.

** Excludes mesh mounted mosaics. Crossville recommends face mounted or edge mounted mosaics for fully submerged applications. Contact your Crossville sales representative for more information.

NOTE: Trim applications will differ from field tile applications for the same series.

For more information on ANSI A362.3 visit our website at <https://www.crossvilleinc.com/Resources/Tile-101/DCOF?tab=1>

Recommended Use

Access Point is recommended for interior floors, interior walls, countertops, exterior walls, pool waterlines and full linings† in both residential and commercial applications. Access Point is not recommended for exterior horizontal surfaces or exterior paving. The Mixed Hex Mosaics and the 2 x 12 Deco pieces are to be used on interior walls only. See CrossvilleInc.com for detailed installation instructions.

† Excludes mesh mounted mosaics

Wet area use for Access Point Mosaics

Crossville® produces the Access Point 2 x 2 mosaics with the Cross-Sheen (UPS) finish. The ANSI A326.3 wet Dynamic COF of Access Point is ≥0.42. Their small sizes ensure frequent grout joints which provides traction and drainage. Crossville cannot control situations involving incorrect installation, improper slope to the drain for elimination of standing water and poor surface cleaning. This information is provided so that customers may make a realistic and informed decision when comparing Access Point to other tile products in wet area environments, such as residential/commercial bathrooms, showers, and interior pool decks.

Care and Maintenance

Regular cleaning is the best way to keep Access Point tile looking good for years to come. Use clean, hot water (combined with a household cleaner for more aggressive cleaning). Rinse thoroughly and dry with a soft cloth. No waxes are needed. More information regarding the care and maintenance of Crossville® products is available at CrossvilleInc.com.

Our Warranty

Crossville Inc. guarantees that its products will meet or exceed the performance specifications outlined in ANSI A137.1 and in the performance data section of the Crossville, Inc. general product catalog. For complete details check our website at CrossvilleInc.com

Information listed here is subject to change. Please refer to CrossvilleInc.com for the latest, most accurate information.

Crossville® Sample Express

Visit the website to learn more:
CrossvilleInc.com/Products/Access-Point

Loose Tile Samples

Sizes may vary depending on product series
Max. of 4 large field tile per order

Standard Shipping

FedEx Ground

CrossvilleInc.com

If you want a better idea of what Crossville tile would look like in a particular room setting, simply visit our website and click on Cross-Vision. This powerful software tool allows you to visualize different types of Crossville tile. In addition, you'll find comprehensive information about Crossville's entire portfolio of products. You can also learn about the latest styles and trends from industry experts, download detailed care and maintenance instructions for our various products, or browse electronic versions of Crossville's product brochures. So whether you need information about Crossville products or tile in general, please visit us at CrossvilleInc.com. Information listed here is subject to change.

Trade Organizations



Environmentally Aware



SECTION 01 2100 - ALLOWANCES

PART 1 GENERAL

1.1 SECTION INCLUDES

- A. Contingency allowance.

1.2 CONTINGENCY ALLOWANCE

- A. Contractor's costs for products, delivery, installation, labor, insurance, payroll, taxes, bonding, equipment rental, overhead and profit will be included in Change Orders authorizing expenditure of funds from this Contingency Allowance.
- B. Funds will be drawn from the Contingency Allowance only by Change Order.
- C. At closeout of Contract, funds remaining in Contingency Allowance will be credited to Owner by Change Order.

1.3 ALLOWANCES SCHEDULE

- A. General Mechanical and Plumbing Allowance: Include an amount of \$20,000.00 (Twenty Thousand Dollars) for unforeseen building conditions as directed by the Architect.
- B. General Electrical Allowance: Include an amount of \$20,000.00 (Twenty Thousand Dollars) for unforeseen building conditions directed by the Architect.
- C. General Fire Alarm Allowance: Include an amount of \$10,000.00 (Ten Thousand Dollars) for unforeseen building conditions directed by the Architect.
- D. Alternate #3 - Include an amount of \$4,000.00 (Four Thousand Dollars) to cap all plumbing in wall and cover as part of the wall repair. Please also see Section 01 2300 Alternates.
- E. Alternate #5 - Include an amount of \$23,000.00 (Twenty-Three Thousand Dollars) to address the directional signage. Please also see Section 01 2300 Alternates.

PART 2 PRODUCTS - NOT USED

PART 3 EXECUTION - NOT USED

END OF SECTION

SECTION 10 2800 - TOILET, BATH, AND LAUNDRY ACCESSORIES

PART 1 GENERAL

1.1 SECTION INCLUDES

- A. Commercial toilet accessories.
- B. Under-lavatory pipe supply covers.
- C. Adult changing stations.

1.2 REFERENCE STANDARDS

- A. ASTM A269/A269M - Standard Specification for Seamless and Welded Austenitic Stainless Steel Tubing for General Service; 2015a.
- B. ASTM A666/A666M - Standard Specification for Annealed or Cold-Worked Austenitic Stainless Steel Sheet, Strip, Plate, and Flat Bar; 2024.
- C. ASTM C1036 - Standard Specification for Flat Glass; 2016.
- D. ASTM C1048 - Standard Specification for Heat-Strengthened and Fully Tempered Flat Glass; 2012.
- E. ASTM E84 - Standard Test Method for Surface Burning Characteristics of Building Materials; 2017.
- F. ASTM G21 - Standard Practice for Determining Resistance of Synthetic Polymeric Materials to Fungi; 2015.
- G. ICC A117.1 - Accessible and Usable Buildings and Facilities; 2017.

1.3 SUBMITTALS

- A. See Section 01 3000 - Submittals and Substitutions for submittal procedures.
- B. Product Data: Submit data on accessories describing size, finish, details of function, and attachment methods.

PART 2 PRODUCTS

2.1 MANUFACTURERS

- A. Commercial Toilet Accessories:
 - 1. American Specialties, Inc: www.americanspecialties.com.
 - 2. Bradley Corporation: www.bradleycorp.com.
 - 3. Georgia-Pacific Professional: www.blue-connect.com.
 - 4. Sova: www.choosesova.com.

2.2 MATERIALS

- A. Accessories - General: Shop assembled, free of dents and scratches and packaged complete with anchors and fittings, steel anchor plates, adapters, and anchor components for installation.
 - 1. Grind welded joints smooth.
 - 2. Fabricate units made of metal sheet of seamless sheets, with flat surfaces.
- B. Keys: Provide 3 keys for each accessory to Owner; master key lockable accessories.
- C. Stainless Steel Sheet: ASTM A666/A666M, Type 304.
- D. Stainless Steel Tubing: ASTM A269/A269M, Grade TP304 or TP316.
- E. Mirror Glass: Tempered safety glass, ASTM C1048; and ASTM C1036 Type I, Class 1, Quality Q2, with silvering as required.
- F. Fasteners, Screws, and Bolts: Hot dip galvanized; tamper-proof; security type.
- G. Expansion Shields: Fiber, lead, or rubber as recommended by accessory manufacturer for component and substrate.

2.3 FINISHES

- A. Stainless Steel: Satin finish, unless otherwise noted.

2.4 COMMERCIAL TOILET ACCESSORIES

- A. Toilet Paper Dispenser: Provided by Owner and installed by the General Contractor.
- B. Paper Towel Dispenser: Provided by the Owner and installed by the General Contractor.
- C. Soap Dispenser: Provided by the Owner and installed by the General Contractor.
- D. Mirrors: Stainless steel framed, 1/4 inch thick tempered safety glass; ASTM C1048.
 - 1. Size: As indicated on drawings.
 - 2. Frame: 0.05 inch angle shapes, with mitered and welded and ground corners, and tamperproof hanging system; satin finish.
 - 3. Backing: Full-mirror sized, minimum 0.03 inch galvanized steel sheet and nonabsorptive filler material.
- E. Grab Bars: Stainless steel, textured surface.
 - 1. Standard Duty Grab Bars:
 - a. Push/Pull Point Load: 250 pound-force, minimum.

- b. Dimensions: 1-1/2 inch outside diameter, minimum 0.05 inch wall thickness, exposed flange mounting, 1-1/2 inch clearance between wall and inside of grab bar.
 - c. Finish: Satin.
 - d. Length and Configuration: As indicated on drawings.
- F. Sanitary Napkin Disposal Unit: Stainless steel, surface-mounted, self-closing door, locking bottom panel with full-length stainless steel piano-type hinge, removable receptacle.
- G. Robe/Coat Hook: Heavy-duty stainless steel, single-prong, rectangular-shaped bracket and backplate for concealed attachment, satin finish. Install on the entry door into E203A, E204A, and E205A.

2.5 UNDER-LAVATORY PIPE AND SUPPLY COVERS

- A. Under-Lavatory Pipe and Supply Covers:
 - 1. Insulate exposed drainage piping including hot, cold, and tempered water supplies under lavatories or sinks to comply with ADA Standards.
 - 2. Exterior Surfaces: Smooth non-absorbent, non-abrasive surfaces.
 - 3. Construction: 1/8 inch flexible PVC.
 - a. Surface Burning Characteristics: Flame spread index of 25 or less and smoke developed index of 450 or less, when tested in accordance with ASTM E84.
 - b. Comply with ICC A117.1.
 - c. Microbial and Fungal Resistance: Comply with ASTM G21.
 - 4. Color: White.
 - 5. Fasteners: Reusable, snap-locking fasteners with no sharp or abrasive external surfaces.

2.6 ADULT CHANGING TABLE

- A. Wall mounted adult changing table, Sova stainless steel model # 75HS0206 or an approved equal.
 - 1. Length: 70 inches.

PART 3 EXECUTION

3.1 EXAMINATION

- A. Verify existing conditions before starting work.
- B. Verify exact location of accessories for installation.

3.2 PREPARATION

- A. Deliver inserts and rough-in frames to site for timely installation.
- B. Provide templates and rough-in measurements as required.

3.3 INSTALLATION

- A. Install accessories in accordance with manufacturers' instructions in locations indicated on drawings.
- B. Install accessories provided by Owner's vendors in accordance with the contract documents.
- C. Install plumb and level, securely and rigidly anchored to substrate.
- D. Mounting Heights: As required indicated on drawings.

3.4 PROTECTION

- A. Protect installed accessories from damage due to subsequent construction operations.

END OF SECTION